



BBA

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8560

PRINT OR TYPE ONLY

1. OWNER JAMES LYNCH ADDRESS AT WELL LOCATION 2791 DAVIS CT.
 MAILING ADDRESS MINDEN NV 89423 MINDEN NV 89423

2. LOCATION NW 1/4 NW 1/4 Sec. 35 T. 14 N/S R. 20 E DOUGLAS County
 PERMIT NO. 21-250-27 Johnson Lane Subdivision Name

Issued by Water Resources Parcel No. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SAND & clay		0	15	
clay & Gravel		15	25	
sand & clay		25	57	
sand & Gravel & clay		57	62	
sand & clay		62	157	
SAND	X	157	177	
SAND & clay		177	205	
SAND	X	205	210	
clay & sand		210	215	
SAND	X	215	219	
SAND & clay		219	230	

8. WELL CONSTRUCTION

Diameter hole 6 inches Total depth 230 feet
 Casing record #1 - 230
 Weight per foot _____ Thickness .167

Diameter	From	To
12 inches	0	50
<u>6 5/8</u> inches	50	230
_____ inches	_____	_____

Surface seal: Yes No Type CEMENT
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation FACTORY
 Size perforation 3X 3/32
 From 205 feet to 225 feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 155 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature 64 ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Kawchack Drilling, Inc. Contractor
 Address Box 536 Gardnerville, NV Contractor
 Nevada contractor's license number 021268
 Nevada contractor's drillers number 1380
 Nevada driller's license number 1425 Actual Driller
 Signed Eddy Kawchack Contractor
 Date 3/3/87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. 15 Draw down 10 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours