WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28280
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8471

1. OWNER JAMES FEDDISH
MAILING ADDRESS Gardnerville, Nevada
ADDRESS AT WELL LOCATION 1328 TANZY CT FISH SPRINGS Gardnerville, NV

2. LOCATION NE ¼ NW ¼ Sec. 3 T. 12 N/S R. 21 E. DOUGLAS County
PERMIT NO. Issued by Water Resources | 35-343-09 Parcel No. | PINE NUTS ESTATES UNIT 1 Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, w/ gravel & small boulders		0	5	5
Gravel & Boulders		5	108	103
Pea gravels w/ water	✓	108	115	7
Boulders + gravel		115	125	10
Pea gravel w/ water	✓	125	135	10
Tight Clay		135	140	5
T.D. 140				

Date started March 16, 1987
Date completed March 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed & gravel packed Well using 450 CFM air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10¾ to 60' inches Total depth 140 feet
9⅞ inches
..... inches
Casing record 6⅝" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3½
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 70 feet below land surface
Flow 25 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A+H Pump Co Contractor
Address 5337 Hiway 50 E Carson City, NV Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] By driller performing actual drilling on site or contractor
Date March 19, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627