

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8530

1. OWNER Eva Rue ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 1372 Butler St 5790 Whiskey Springs Rd  
Reno, Nv 89512 Lot 7 Unit 1 11-2-1-11  
 2. LOCATION SE 1/4 1/4 Sec. 11 T. 22 N/S R. 21 E Washoe County  
 PERMIT NO. 77-110-07 Parcel No. \_\_\_\_\_ Subdivision Name Palomino Valley  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock and sands		0	24	24
Green, red and brown volcanic rock		24	200	176
T.D. 200				

8. 10" -50" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 196 feet

Casing record 6 5/8 inches

Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+1</u> feet	<u>196</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout

Depth of seal 53 feet

Gravel packed: Yes  No

Gravel packed from 53 feet to 196 feet

Perforations:

Type perforation 3/32 X 3 factory

Size perforation 3/32 X 3

From 176 feet to 196 feet

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3/19/87, 19\_\_\_\_

Date completed 3/19/87, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

9. WATER LEVEL

Static water level 110' feet below land surface

Flow 20+ G.P.M. P.S.I. \_\_\_\_\_

Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling and Well Service, Inc.

Address 2255 Glendale Ave. Sparks, Nv 89431

Nevada contractor's license number 15291 issued by the State Contractor's Board

Nevada contractor's driller's number 1132 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511 Division of Water Resources, the on-site driller

Signed Roger M. Thrall By driller performing actual drilling on site or contractor

Date Roger M. Thrall 3/23/87

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours