

OFFICE USE ONLY  
 Log No. 28302  
 Permit No. \_\_\_\_\_  
 Basin 7226

CCAB

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7872

1. OWNER John Nance ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 316 California Ave. #105 11900 Chesapeake  
Reno, NV 89509 Lemmon Valley  
 2. LOCATION SW 1/4 SW 1/4 Sec. 15 T 21N N/S R. 19 E Washoe County \_\_\_\_\_  
 PERMIT NO. 2926 080-323-03 Hepner subdivision # 3  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand clay		0	20	
sand clay gravel		20	40	
sand clay rock		40	60	
sand clay gravel		60	80	
sand clay gravel		80	100	
sand gravel	xx	100	120	
sand clay gravel		120	140	
sand gravel rock		140	162	

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 162 feet  
8 inches  
8 inches  
 Casing record 156 X 8 5/8  
 Weight per foot 9-11 Thickness \_\_\_\_\_  

Diameter	From	To
<u>12 1/4</u> inches	<u>0</u> feet	<u>162</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 162 feet  
 Perforations:  
 Type perforation saw cut  
 Size perforation 5/32 X 4"  
 From 140 feet to 162 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started March 17, 1987  
 Date completed March 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 90-100 feet below land surface  
 Flow good G.P.M. 18-25 P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Sierra Pump & Drilling  
Contractor  
 Address 4639 Highway 50 East Carson City  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 012236-B  
 Nevada contractor's driller's number issued by the Division of Water Resources 1393  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1393  
 Signed Quito Blackwood  
By driller performing actual drilling on site of contractor  
 Date 3-20-87