

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8498

1. OWNER MERL JESSOP ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 10925 Osage Rd. \_\_\_\_\_  
Reno, NV 89506 \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec. 25 T. 21N. N/S R. 18 E. Washoe County  
 PERMIT NO. 86-192-01 Parcel No. \_\_\_\_\_ Subdivision Name Silver Knolls  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil		0	1/2	1/2
Brown clay		1/2	27	26 1/2
Soft zone		27	37	10
Brown sandy clay		37	63	26
Soft zone		63	66	3
Brown clay		66	88	22
Soft zone		88	91	3
Brown clay		91	105	14
Soft zone	X	105	116	11
Brown clay		116	117	1
Soft zone	X	117	121	4
Brown clay		121	123	2
Soft zone		123	125	2

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 125 feet  
6 inches  
6 inches

Casing record 125 ft. steel casing installed.  
 Weight per foot \_\_\_\_\_ Thickness 156

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>125</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 125 feet

Perforations:  
 Type perforation FACTORY SAWED SLOT  
 Size perforation 3/32 x 3 x 6 around  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 3-17-87, 19\_\_\_\_  
 Date completed 3-17-87, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 30 feet below land surface  
 Flow 25 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Address P.O. Box 12370, Reno, Nv 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908  
 issued by the Division of Water Resources  
 Nevada driller's license number 923  
 issued by the Division of Water Resources, the on-site driller  
 Signed Wayne C. Beckman  
 By driller performing actual drilling on site or contractor  
 Date March 18, 1987

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours