WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28309
Permit No.
Basin 7-92a

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8497

1. OWNER LAYNE & SUSAN LISSER
MAILING ADDRESS 948 Primrose
Reno, NV 89509-1805

ADDRESS AT WELL LOCATION
Red Rock Road
Reno, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 7 T. 21N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 89-100-01 (Parcel No.) Red Rock Estaes (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	½	½
Brown clay		½	2	1½
Soft brown sand		2	5	3
Brown clay		5	34	29
Soft zone		34	36	2
Brown sandy clay		36	109	73
Soft zone		109	112	3
Brown clay mixed with Decomposed Granite		112	174	62
Brown clay		174	184	10
Soft zone		184	187	3
Brown clay		187	189	2
Soft zone		189	194	5
Brown sandy clay with DG & Quartz		194	204	10
Soft zone		204	224	20
Brown sandy clay with	DG	224	292	68
Soft zone		292	294	2
Brown sandy clay with	DG	294	304	10
Soft zone		304	307	3
Brown sandy clay with	DG	307	333	26
Soft zone	X	333	337	4
Brown sandy clay with	DG	337	340	3
Soft zone		340	341	1
Brown sandy clay with	DG	341	355	14
Soft zone	X	355	370	15
Brown clay		370	375	5

Date started 3-11-87, 19
Date completed 3-13-87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 375 feet
6 inches
inches
Casing record 375 ft. steel casing insttalled
Weight per foot Thickness .156

Diameter	From	To
6 5/8 inches	0 feet	375 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 375 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 6 around
From 328 feet to 368 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 272 feet below land surface
Flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date March 18, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627