WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28345
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7004

1. OWNER Auro Pagliai
MAILING ADDRESS 8915 San Marco
Sterling Hgts, Mich 48078

ADDRESS AT WELL LOCATION
6180 Phelps Lane
Fallon, Nevada 89406

2. LOCATION SE ¼ NE ¼ Sec. 30 T. 19 N/S R. 29 E. Churchill County
PERMIT NO. NONE (Issued by Water Resources) | NONE (Parcel No.) | NONE (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden	0'	0	7	7
Cemente Gravel + Clay	0'	7	42	35
Clay, Gray	0'	42	48	6
Gravel, Gray	12'	48	55	7
Sand, Brown, Course	10'	55	60	5
Pea Gravel + Sand	10'	60	67	7
Clay, Brown, Hard	0'	67	69	2
Gravel, Large	17'	69	90	21
Clay, Brown	0'	90	92	2
Sand, Fine, Clay, Brown	0'	92	110	18
Clay, Gray	0'	110	113	3
Sand + Clay mixed	0'	113	115	2
Clay, gray, + Sand	0'	115	128	13
Clay, Brown	0'	128	130	2
Clay, gray	0'	130	136	6
Clay, Brown	0'	136	138	2
Red + Black Gravel Dry	0'	138	138½	½
Sand, Gray + Clay	0'	138½	143	4½
Brown + gray Clay + Sand	17'	143	144	1
Gravel - Static water level	20'	144	144½	½
Clay, Brown + gray Sand	0	144½	152	7½
Sand, Brown, Course	0	152	152½	½
Clay, Brown	0	152½	168	15½
Sand + Clay Brown	0	168	174	6
Pea Gravel "Pump test" no water	25	174	175	1
Clay + Brown Sand	0	175	178	3
Sand, Brown Course	14'-3"	178	181	3

Date started 3-3, 1987
Date completed 3-13, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	20	2'-3"	7-NO-Sand
3600	50	6'-2"	4hr-Some Sand
note! Pump well at 20 gal. per. min.			
Set pump at 40'			
Very good well			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 181 feet
..... inches
..... inches
Casing record 182'-1¼" - 18" above ground level
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+ 18" feet	181 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 25 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 180 feet to 181 feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 5"
From 176 feet to 181 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 14'-3 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald L. Olson
By driller performing actual drilling on site or contractor
Date 3-13-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627