WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28357
Permit No.
Basin 8-104

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8986

1. OWNER Richard Beaudette
MAILING ADDRESS 980 Ruby Lane Carson City, NV 89701
ADDRESS AT WELL LOCATION 980 Ruby Lane Carson City, NV 89701

2. LOCATION NE ¼ NW ¼ Sec. 5 T. 15 N/S R. 20 E Carson City County
PERMIT NO. ..... Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☑ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand fill-up in original drilled well		90	115	25
Dark grey to black sand stone		115	137	22
Tan brown sand stone, small amount of water	✓	137	146	9
Grey sandstone w/fractures carrying H2O	✓	146	180	36
T.D. 180				
Original well drilled by Meyers Drilling				

Date started 4-6, 1987
Date completed 4-6, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 1/8 inches Total depth 180 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness

Diameter	From	To
5 inches	80 feet	180 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☐ No ☐ Type
Depth of seal Unknown feet
Gravel packed: Yes ☐ No ☐
Gravel packed from Unknown feet to ..... feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 160 feet to 180 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 56 feet below land surface
Flow 20 G.P.M. ..... P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A&H Pump Co
Contractor
Address Carson City, NV
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature]
By driller performing actual drilling on site or contractor
Date 4-5-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627