



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8535

OWNER Niles Wood ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 20367 Bryand St 4590 Tybo Rd  
Canoga Park, Ca 91306  
 LOCATION SE 1/4 SW 1/4 Sec 4 T 17 N/S R 21 E Storey County \_\_\_\_\_  
 PERMIT NO. 03-393-07 — Highland Ranches Lot 459  
 Issued by Water Resources Parcel No. Subdivision Name

TYPE OF WORK		4. PROPOSED USE		5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Cable <input type="checkbox"/>	Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>
					air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
purple clay brown				
yellow & purple sand		0	16	16
purple & white rock with small amount of clay		16	35	19
purple white gray & brown rock hard		35	88	53
purple white reddish brown & yellow weathered rock		88	110	22
purple, blue gray & white rock		110	142	32
green white & brown rock with some weathered zones		142	485	
very light green white and brown weathered rock		485	517	32
T.D. 517'				

8. 10" - 54" WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 510 feet

Casing record 6 5/8 inches

Weight per foot 10.78 & 12.92 Thickness 156 & 188

Diameter	From	To
<u>6 5/8</u> inches	<u>+ 2</u> feet	<u>510</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type grout

Depth of seal 52 feet

Gravel packed: Yes  No

Gravel packed from 52 feet to 517 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4/6/87, 19\_\_\_\_

Date completed 4/9/87, 19\_\_\_\_

9. WATER LEVEL

Static water level 280 feet below land surface

Flow 20+ G.P.M. P.S.I. \_\_\_\_\_

Water temperature cold °F Quality \_\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop for 3 1/2 hrs			

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.  
 Contractor

Address 2255 Glendale Ave. Sparks, Nv 89431  
 Contractor

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132  
 issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1511

Signed Roger M. Thibault  
 By driller performing actual drilling or site contractor

Date 4/10/87

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours