



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8989

1. OWNER Richard Windham
 MAILING ADDRESS 3139 Champion Carson City Nevada
 ADDRESS AT WELL LOCATION Sam Clemens

2. LOCATION SE 1/4 SW 1/4 Sec. 25 T. 17 S. R. 22 E STOREY County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	3	3
Cemented Gravel, tan	✓	3	290	287
Reproduction				
First Water				
at 263, 2-3GPM				
Next water at				
280, 3-GPM				
Next water at				
387, 5-GPM				
TDI 290 FT				

8. WELL CONSTRUCTION
 Diameter.....inches Total depth 290 feet
inches
inches
 Casing record 6 5/8 O.D.
 Weight per foot 11.7 Thickness 1.56
 Diameter From To
6 5/8 inches +2 feet 290 feet
inchesfeetfeet
inchesfeetfeet
inchesfeetfeet
inchesfeetfeet
 Surface seal: Yes No Type Concrete
 Depth of seal 53 feet
 Gravel packed: Yes No
 Gravel packed from 53 feet to 290 feet
 Perforations:
 Type perforation Factory Mill slot
 Size perforation 3/8" x 3/4"
 From 260 feet to 280 feet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet
 Fromfeet tofeet

9. WATER LEVEL
 Static water level 290 feet below land surface
 Flow 18 G.P.M. P.S.I.
 Water temperature 66 °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Frank Jumbo Co
3351 Highway 38 #5
 Address Carson City Nevada Contractor
 Nevada contractor's license number issued by the State Contractor's Board 23295
 Nevada contractor's driller's number issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
 Signed Frank Jumbo
 By driller performing actual drilling on site or contractor
 Date April 16, 1987

Date started April 13, 1987
 Date completed April 15, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Developed and gravel packed</u>			
<u>with 250 CFM air lift</u>			
<u>2 1/2 hrs</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours