

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 7870

1. OWNER G. J. Dokter ADDRESS AT WELL LOCATION
 MAILING ADDRESS P.O. Box 1177 11345 Silver Lane
Dayton, NV 89403 Stage Coach, NV

2. LOCATION $\frac{1}{4}$ $\frac{1}{4}$ Sec. 17 T. 17N N/S R. 23 E. Lyon County
 PERMIT NO. 14-19-392-03 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand clay mix		0	20	
sand clay gravel		20	40	
sand clay rock		40	60	
sand clay rock		60	80	
sand gravel		80	100	
sand gravel		100	120	
sand gravel		120	140	
sand clay gravel		140	162	

8. WELL CONSTRUCTION

Diameter 9 7/8 inches Total depth 162 feet

Casing record 188 X 8 5/8 X 5/32

Weight per foot 14.11 Thickness 5/32

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>162</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 162 feet

Perforations:

Type perforation 188 X 8 5/8 saw cut

Size perforation 5/32 X 2 1/2

From 130 feet to 162 feet

From _____ feet to _____ feet

Date started 3-4 19 87
 Date completed 3-4 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.	Draw down	feet	hours

9. WATER LEVEL

Static water level 40 feet below land surface

Flow good G.P.M. 30-40 P.S.I.

Water temperature COld °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump & Drilling
 Contractor

Address 4639 Highway 50 East Carson City
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 012236-B

Nevada contractor's driller's number issued by the Division of Water Resources 1393

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1393

Signed Curto Blumhagen
 By driller performing actual drilling on site or contractor

Date _____