

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 8547

PRINT OR TYPE ONLY

1. OWNER SHIRLEY MOORE ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2600 Spinnaker Drive 2400 Kinney Lane  
Reno, NV 89509 Reno, NV 89511  
 2. LOCATION E 1/2 1/4 1/4 Sec. 2 T. 18N. N/S R. 19 E. Washoe County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 41-258 09 Subdivision Name Cottonwood Est. SW Reno  
 Issued by Water Resources \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

| Material                   | Water Strata | From | To  | Thick-ness |
|----------------------------|--------------|------|-----|------------|
| Loose volcanic rock        |              | 0    | 1   | 1          |
| Gray volcanic rock         |              | 1    | 27  | 26         |
| Soft zone                  |              | 27   | 28  | 1          |
| Gray volcanic rock         |              | 28   | 47  | 19         |
| Soft zone                  |              | 47   | 49  | 2          |
| Gray volcanic rock         |              | 49   | 90  | 39         |
| Fracture zone(app.20GPM) X |              | 90   | 96  | 6          |
| Gray volcanic rock         |              | 96   | 116 | 20         |
| Soft zone                  |              | 116  | 117 | 1          |
| Gray volcanic rock         |              | 117  | 118 | 1          |
| Red volcanic rock          |              | 118  | 130 | 12         |
| Fracture                   | X            | 130  | 132 | 2          |
| Red volcanic rock          |              | 132  | 145 | 13         |
| Fracture                   | X            | 145  | 148 | 3          |
| Red volcanic rock          |              | 148  | 162 | 14         |
| Fracture                   | X            | 162  | 169 | 7          |
| Red volcanic rock          |              | 169  | 175 | 6          |

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 175 feet  
6 inches  
 Casing record 175' steel casing installed  
 Weight per foot \_\_\_\_\_ Thickness .156  

| Diameter            | From          | To              |
|---------------------|---------------|-----------------|
| <u>6 5/8</u> inches | <u>0</u> feet | <u>175</u> feet |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |
| _____ inches        | _____ feet    | _____ feet      |

 Surface seal: Yes  No  Type cement  
 Depth of seal \_\_\_\_\_ 52 feet  
 Gravel packed: Yes  No   
 Gravel packed from \_\_\_\_\_ 52 feet to 175 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 130 feet to 170 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 4-8-87 19\_\_\_\_  
 Date completed 4-8-87 19\_\_\_\_

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

9. WATER LEVEL  
 Static water level 45 feet below land surface  
 Flow 85 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, NV 89510 Contractor  
 Nevada contractor's license number 22549 issued by the State Contractor's Board  
 Nevada contractor's driller's number 908 issued by the Division of Water Resources  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date April 11, 1987

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours