WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28381
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8724

1. OWNER Eldon Smith
MAILING ADDRESS 6406 Paul Place
Fallon, Nv. 89406

ADDRESS AT WELL LOCATION
Same as owner

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. None (Issued by Water Resources) | File #137200 (Parcel No.) | Lot 4 of BKD Bell Smith Land Division (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden	0	0	2	2
Clay, Brown	0	2	24	22
Sand, Brown Coarse	10	24	25	1
Clay, Brown	0	27	38	11
Sand, Fine Brown with mica	8	38	43	5
Clay, Brown	0	43	58	15
Gravel	0	58	59	1
Clay, Brown	0	59	63	4
Sand, Brown with gravel	9	63	66	3

Date started 4-12, 1987
Date completed 4-16, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	15	6'	3½ hrs
Set Pump at 40'			
Do not Pump over 15 g.p.m.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 66 feet
..... inches
..... inches
Casing record 68
Weight per foot 17.02 Thickness .1250

Diameter	From	To
6 inches	+2 feet	66 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 25 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 64 feet to 66 feet

Perforations:
Type perforation Torch.
Size perforation 5/32 x 4"
From 61 feet to 66 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 9 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality Excellent

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald U. Olson
(By driller performing actual drilling on site or contractor)
Date 4-18-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627