

ABCD

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8534

PRINT OR TYPE ONLY

1. OWNER Ahmed Imtiaz ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1659 Wedekind Rd # B 3430 Rolling Ridge Ct
Reno, Nv 89512
 2. LOCATION 1/4 NE 1/4 Sec 14 T. 20 N/S R. 19 E Washoe County _____
 PERMIT NO. 82-511-06 Lot 16 Golden Valley Estates
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
DG & dirt with sand		0	10	10
DG Brown yellows & white		10	17	7
Green Brown & yellow rocks & sand		17	24	7
Reddish brown green & white hard rock		24	30	6
yellow red brown & white volcanic rock		30	38	8
Brown & yellow sand with white clay		38	42	4
Black red green & white rock		42	58	16
Brown yellow white and green rock		58	117	59
T.D. <u>117</u>				

8. 10" - 55' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 117 feet

Casing record 6 5/8 inches

Weight per foot 10.38 & 12.52 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>117</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout

Depth of seal 54 feet

Gravel packed: Yes No

Gravel packed from 54 feet to 117 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 3

From 97 feet to 117 feet

From _____ feet to _____ feet

Date started 4/14/87, 19____
 Date completed 4/14/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air for 2 1/2 hrs to clean and develop.			

9. WATER LEVEL

Static water level 90 feet below land surface

Flow 40+ G.P.M. _____ P.S.I.

Water temperature cold °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.
Contractor

Address 2255 Glendale Ave. Sparks, Nv 89431
Contractor

Nevada contractor's license number 15291
 issued by the State Contractor's Board

Nevada contractor's driller's number 1132
 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date 4/17/87

BAILER TEST

G.P.M.	Draw down	feet	hours