

OFFICE USE ONLY
 Log No. 28386
 Permit No. _____
 Basin 7-92a

WELL DRILLER'S REPORT

Please complete this form in its entirety

8548

PRINT OR TYPE ONLY

NOTICE OF INTENT NOXXXXXX

1. OWNER MR & MRS BETSCHART ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 10790 Red Rock Road Same
Reno, NV 89506
 2. LOCATION NW 1/4 NW 1/4 Sec 25 T 21N N/S R. 18 E Washoe County
 PERMIT NO. 086-163-10 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input checked="" type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Granite sands	X	98	105	7
Gray clay		105	110	5
Fine sands		110	111	1
Gray clay		111	120	9
Gray granite sands	X	120	130	10
Green clay		130	131	1
Med. coarse sands, granite	X	131	139	8
Green clay		139	140	1

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 140 feet
 _____ inches
5 inches
 Casing record 140' steel casing installed
 Weight per foot _____ Thickness .156
 Diameter From To
5" liner inches _____ 0 feet _____ 140 feet
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type N/A
 Depth of seal _____ N/A feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to N/A feet

Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 5 around
 From 95 feet to 135 feet
 From _____ feet to _____ feet

Date started 4-10-87, 19____
 Date completed 4-10-87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours
G.P.M. _____	Draw down _____ feet	_____ hours

9. WATER LEVEL

Static water level 81 feet below land surface
 Flow 30 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc. Contractor
 Address P.O. Box 12370, Reno, NV 89510 Contractor
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada contractor's driller's number 908
 issued by the Division of Water Resources
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed Wayne C. Hedman
 By driller performing actual drilling on site or contractor
 Date April 14, 1987