WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28293
Permit No. 35009
Basin DIAMOND V. 10-153

1. OWNER Max Allen ADDRESS PO Box 297 Eureka NV 89316

2. LOCATION SW ¼ NW ¼ Sec. 21 T. 21 N R. 53 E. Eureka County
PERMIT NO. 18993

3. TYPE OF WORK
New Well ☑ Replacement Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐ Reverse

6. LITHOLOGIC LOG

S+G = Sand + Gravel

Material	Water Strata	From	To	Thickness
Top Soil		0	4	
Sandy loam		4	21	
S+G		21	34	
Clay + S+G layers		34	58	
S+G with 3' rock		58	70	
Dry white clay		70	77	
S+G		77	83	
clay		83	87	
S+G		87	100	
Hard dry clay		100	105	
Fine Brown Sand		105	107	
clay		107	109	
S+G		109	139	
clay		139	145	
S+G		145	155	
clay		155	157	
S+G		157	180	
clay		180	188	
S+G Cobbles to 8" dia		188	228	
clay		228	235	
S+G		235	240	
Hard Cemented Gravel		240	240.3	

Date started 12-18, 19 83
Date completed 12-19, 19 83

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 29 inches Total depth 240 feet
Casing record
Weight per foot ..... Thickness .250

Diameter		From		To	
16	inches	0	feet	240	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 240 feet

Perforations:
Type perforation Roscoe Moss Full Flow
Size perforation STD Flo
From STD FLO 140 feet to 168 feet
From Full Flow 168 feet to 240 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level ..... Feet below land surface .....
Flow ..... G.P.M. .....
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Plaskett Irr Co.
Address PO Box 10 Eureka NV 89316
Nevada contractor's license number 11882
Nevada driller's license number 706
Signed Walter J Plaskett
Date 12-20-83

USE ADDITIONAL SHEETS IF NECESSARY

O-627