

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7166

PRINT OR TYPE ONLY

1. OWNER CHARLIE HAITLE ADDRESS AT WELL LOCATION SAME AS Subdivided
 MAILING ADDRESS 4655 Testolia Rd. FALLON, NV. 89406
 2. LOCATION Nd 1/4 SE 1/4 Sec 6 T 18 N/S R 29 E Churchill County
 PERMIT NO. NONE Issued by Water Resources Parcel No. 06-732-54 Callahan PARCE 13 of Robert Callahan Parcel
MAP 620 THE WILBIRD F.6 No. 176823

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden	0	0	1	1
Clay Brown	0	1	27	26
Sand, GREEN, FINE	10	27	33	
Sand, GRAY, Strong ODER	10	33	40	7
Sand, GRAY, COARSE				
Strong ODER	12	40	45	5
Sand + clay, Black	0	45	53	8
Clay, Black + gray				
Sand	0	53	73	20
Clay, GRAY + Sand	0	73	93	20
Sand, GRAY, Red, white and pea				
GRAVEL, VERY LITTLE				
ODER	14	93	94'-8 7/8"	1'-8 7/8"

8. WELL CONSTRUCTION
 Diameter 6 inches Total depth 94'-8 7/8" feet
 Casing record +16" to 94'-8 7/8"
 Weight per foot 17.02 Thickness .250
 Diameter 6 inches From +16" To 94'-8 7/8"
 Surface seal: Yes No Type NEAT
 Depth of seal 25 feet
 Gravel packed: Yes No
 Gravel packed from 91' feet to 94'-8 7/8" feet

Perforations:
 Type perforation Torch.
 Size perforation 5/32 + 4"
 From 91'-8 7/8" feet to 94'-8 7/8" feet
 From _____ feet to _____ feet

Date started 3-31, 1987
 Date completed 4-4-, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>3600</u>	<u>16</u>	<u>32</u>	<u>4 HRS</u>
<u>SET Pump AT 60'</u>			
<u>DONT PUMP ODER 16 9PM.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL
 Static water level 81-5" AFTER Pumping feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good, just a little ODER.

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water-Rite Well Drilling Contractor
 Address P.O. Box 883 Fallon, NV. 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0023978
 Nevada contractor's driller's number issued by the Division of Water Resources 1473
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
 Signed Gerald U. Olson
 By driller performing actual drilling on site or contractor
 Date 4-4-87