WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28423
Permit No.
Basin 212

NOTICE OF INTENT NO. 2278

PRINT OR TYPE ONLY

1. OWNER Ruth Specht
MAILING ADDRESS 4310 Blue D. Rd.

ADDRESS AT WELL LOCATION

2. LOCATION W½ NE¼, NE ¼ Sec. 18 T. 22 S R. 61 E Clark County
PERMIT NO. SW¼ (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Hard pan		2	6	4
Tight rocks & soil		6	80	74
Pink colored cemented gravel		80	200	120
Light colored cemented gravel		200	280	80
Light colored sand	280	280	284	4
Reddish clay with gravel & sand	284	284	320	36
Cemented gravel & rocks	320	350		30

RECEIVED APR 7 1987 Div. of Water Resources Branch Office - Las Vegas, NV

Date started June 1, 1985, 19 85
Date completed Nov. 10, 1985, 19 85

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 350 feet
Casing record
Weight per foot 14 lbs. Thickness .156

Diameter		From	To
8 5/8 O.D.	inches	0 feet	350 feet
	inches	feet	feet
	inches	feet	feet
	inches	feet	feet
	inches	feet	feet
	inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 350' feet

Perforations:
Type perforation Slot
Size perforation 1/8" x 3"
From ..... feet to ..... feet
From 290' feet to 350' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 262' feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 65 °F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H. V. Weimer (Contractor)
Address 9051 Mohawk L.V. Nev. (Contractor)
Nevada contractor's license number 5962 A
Nevada contractor's drillers number 171
Nevada driller's license number 171
Signed H. V. Weimer (Actual Driller / Contractor)
Date Nov. 30, 1985

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434