WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28428
Permit No. 49170
Basin 212
NOTICE OF INTENT NO. 1274

PRINT OR TYPE ONLY

1. OWNER Dave Cuddie + Mike Enfield
MAILING ADDRESS 9465 Edmond, L.V. Nev. 89118
ADDRESS AT WELL LOCATION Dave Cuddie + Mike Enfield 9465 Edmond L.V. Nev. 89118

2. LOCATION ~~NW~~ ¼ ¼ Sec. 24 T. 22 N/S R. 60 E. County
PERMIT NO. (Issued by Water Resources) | Parcel No. #1 | File 48 Subdivision Name 433

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☑ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Caliche		2	42	40
Cemented gravel		42	152	110
Hard lime Shelf		152	158	6
Cemented gravel		158	298	140
Loose Sand and gravel	298	298	309	11
reddish clay with little sand	309	309	329	20
Cemented gravel with loose strata of sand & rocks	329	329	400	71

RECEIVED
JAN 03 1990
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Jan. 2, 1985
Date completed Feb. 10, 1985

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 8 inches Total depth 400' feet
inches
inches
Casing record 8 5/8" O.D. x 400'
Weight per foot 8 15 lbs Thickness .219

Diameter	From	To
8 5/8" inches	0 feet	400 feet
8 inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete grout
Depth of seal ..... feet
Gravel packed: Yes ☐ No ☑
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation 1/8" x 4" - vertical slot
Size perforation 1/8" x 4"
From 340' feet to 400' feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 278 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 70 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Weimer Drilling (Contractor)
Address 9051 Mohawk L.V. Nev. 89118 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5963 A
Nevada contractor's driller's number issued by the Division of Water Resources 171
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 171
Signed H. K. Weimer (By driller performing actual drilling on site or contractor)
Date April 3, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627