WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28445
Permit No.
Basin WASHOE V. — 89

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8987

1. OWNER Charles Jennings
MAILING ADDRESS 2010 Lakeshore Drive Carson City, Nev
ADDRESS AT WELL LOCATION New Washoe City 2900 Lakeshore Drive Carson City Nevada

2. LOCATION SE ¼ SW ¼ Sec. 31 T. 17 N/S R. 20 E WASHOE County
PERMIT NO. W Cty 2983 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	4	4
Brown Sandstone		4	19	15
Grey Silty Sandstone with Clay seams		19	69	50
Soft Grey to Brown Sand Stone with Gravels Carrying water	✓	69	118	49
Soft to Medium Hard brown, tight Clay		118	120	2
T.D. 120'				
Deepened by Well log 122710				

Date started April 29, 19 87
Date completed April 30, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed with Clean Water to remove drill mud & to Grout Pack. Sealed with Freshia 30+ GPM From 70'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10¾ inches Total depth 120 feet
inches
inches
Casing record 6⅝ O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6⅝ inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 120 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 1/16" X 3½"
From 95 feet to 115 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow 30+ G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Pump Co Contractor #3
Address 551 Kewanee Carson City, Nev 89701
Contractor
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources the on-site driller 1472
Signed Clinton Betts
By driller performing actual drilling on site or contractor
Date May 1, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627