

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8525

1. OWNER Dean White ADDRESS AT WELL LOCATION 7005 Lakeside Dr.
 MAILING ADDRESS 115 Casazza St.
Reno, Nv 89502

2. LOCATION SW 1/4 SW 1/4 Sec 36 T 19 N/S R 19 E Washoe County
 PERMIT NO. 41-100-43 Parcel No. Subdivision Name

Issued by Water Resources

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/> Air <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Blue gray and brown rock		0	105	105
Reddish brown and dark green, tan volcanic rock		105	127	22
Brown-red-gray volcanic rock		127	145	18
Brown, yellow, green volcanic rock		145	158	17
gray, yellow, red volcanic rocks		158	220	62
First water 198'				
5 GPM				
198 - 220 - 25+ GPM				

8. 10" - 50' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 220 feet

Casing record 6 5/8

Weight per foot 10.78 & 12.92 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+6</u> feet	<u>220</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type grout

Depth of seal 67 feet

Gravel packed: Yes No

Gravel packed from 67 feet to 218 feet

Perforations:

Type perforation factory

Size perforation 3/32 X 2

From 198 feet to 218 feet

From _____ feet to _____ feet

Date started 2/12/87, 19____
 Date completed 2/16/87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew well with air to clean and develop.			

9. WATER LEVEL

Static water level 180 feet below land surface

Flow 25+ G.P.M. P.S.I.

Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc.

Address 2255 Glendale Ave. Sparks, Nv 89431

Nevada contractor's license number 15291 issued by the State Contractor's Board

Nevada contractor's driller's number 1132 issued by the Division of Water Resources

Nevada driller's license number issued by the 1511 Division of Water Resources, the on-site driller

Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor

Date 2/18/87

BAILER TEST

G.P.M.	Draw down	feet	hours