WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28447
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8463

1. OWNER June F. Tunall
MAILING ADDRESS 4750 Austin Hwy. Fallon, NV. 89406
ADDRESS AT WELL LOCATION Same as owner

2. LOCATION SE ¼ NW ¼ Sec. 35 T. 19 N/S R. 29 E Churchill County
PERMIT NO. None (Issued by Water Resources) | 7-981-01 (Parcel No.) | None (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☒ Rotary ☐ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Over burden	0	0	7	7
Sand, Brown	7	7	10	3
Clay, Brown	0	10	38	28
Clay, Black	0	38	58	20
Clay, + Sand, Gray	0	58	90	32
Clay, Brown	0	90	91	1
Clay, Gray	0	91	93	2
Clay, Brown	0	93	96	3
Clay, Gray	0	96	102	6
Clay, Brown	0	102	116	18
Clay, Light Gray	0	116	118	2
Clay, Brown	0	118	127	9
Clay, Green	0	127	133	6
Clay, Black	0	133	135	2
Green, Sand, Dry	0	135	143	8
Clay, Black	0	143	165	22
Clay, Green	0	165	171	6
Clay, Gray	0	171	178	7
Sand + Clay Gray	0	178	188	10
Clay, Gray	0	188	200	12
Clay, Green	0	200	209	9
Green, Sand, Dry	0	209	215	6
Clay, Brown	0	215	225	10
Clay, Green	0	225	235	10
Sand, Dark Brown Dry	0	235	240	5
~~Clay~~ Sand, Fine Gray	15	240	250	10

Date started 4-16, 1987
Date completed 4-28, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	15	15	12

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 250 feet
inches
inches
Casing record 235
Weight per foot 17.02 Thickness .250

Diameter	From	To
6 inches	+18" feet	235 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 235 feet to 250 feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4
From 232 feet to 235 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 13'-7" feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature 70 °F Quality Poor - Color + Odor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board C023478
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-25-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627