WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28451
Permit No.
Basin 8-01

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8725

1. OWNER WARREN G. BECKHAM
MAILING ADDRESS 780 AIRPORT RD. FALLON, NV. 89406
ADDRESS AT WELL LOCATION SAME AS OWNER

2. LOCATION SE ¼ SE ¼ Sec. 19 T. 19 N/S R. 29 E. CHURCHILL County
PERMIT NO. NONE (Issued by Water Resources) | 07-511-04 (Parcel No.) | NONE. (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
OVERBURDEN	0	0	1	1
CLAY, BROWN	0	1	28	27
SAND, BROWN COARSE	28	28	29	1
QUICKSAND, BROWN	28	29	38	9
SAND, GRAY, FINE	0	38	42	6
CLAY, GRAY, GREEN	0	42	47	5
CLAY, BLACK	0	47	53	6
CLAY, GRAY	0	53	60	7
SAND, FINE, GRAY	0	60	62	2
CLAY, GRAY	0	62	73	11
CLAY, BLACK	0	73	74	1
SAND, BROWN COARSE WITH GRAVEL	28	74	88½	14½

Date started 5-1, 1987
Date completed 5-5, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
3600	12	38	2 hrs.
SET PUMP AT 75'			
DO NOT PUMP OVER 10 GPM.			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 88½ feet
inches
inches
Casing record 90' TOTAL
Weight per foot 17.02 Thickness .125"

Diameter	From	To
6 inches	+18" feet	88½ feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type NEAT
Depth of seal 25 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 87½ feet to 88½ feet

Perforations:
Type perforation TORCH.
Size perforation 5/32 x 4"
From 85½ feet to 88½ feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 28 feet below land surface
Flow — G.P.M. — P.S.I.
Water temperature Cold °F Quality EXCELLENT

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WATER-RITE WELL DRILLING (Contractor)
Address P.O. BOX 883 FALLON, NV. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board CC23987
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald A. Olson (By driller performing actual drilling on site or contractor)
Date 5-5-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627