WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28464
Permit No.
Basin 8-105

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8988

1. OWNER John Stone
MAILING ADDRESS 6660 Gentry Lane, Carson City, Nevada 89701
ADDRESS AT WELL LOCATION None, 1/4 E OF MOTTSVILLE CEMETERY, Gardnerville, Nevada
2. LOCATION NW ¼ NE ¼ Sec. 3 T. 12 N/S R. 19 E/W Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name None

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden Sand & D.G.		0	6	6
D.G. interspersed with brown to tan sand		6	60	54
Compact, tight D.G.		60	84	24
D.G. with Granite	✓	84	120	36
T.D. 120 FT				

Date started May 6, 19 87
Date completed May 12, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
20GPM	From 10'	DD = 10'	
20GPM	From 40'	DD = 10'	
Flushed with clear water to remove mud & clean screen			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 120 feet
..... inches
..... inches
Casing record 6 5/8 O.D.
Weight per foot 14.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	110 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 58 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 58 feet to 110 feet

Perforations:
Type perforation 01 S.S. Johnson
Size perforation 01 S.S. Johnson
From 90 feet to 110 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 12 feet below land surface
Flow 20+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO (Contractor)
Address Carson City, NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23245
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed Quentin R. Butte (By driller performing actual drilling on site or contractor)
Date 5/13/87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627