WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28465
Permit No.
Basin 8-105

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8994

1. OWNER Don Booker
MAILING ADDRESS P.O. Box 960
Gardnerville, Nevada

ADDRESS AT WELL LOCATION Run Around Ranch
827 Foothill Road
Gardnerville, Nevada

2. LOCATION SW ¼ SW ¼ Sec. 14 T. 12 N/S R. 19 E. Douglas County

PERMIT NO. ..... Issued by Water Resources | 19-200-04 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden With Boulders		0	6	6
Fractured D.G. w/ large boulders		6	87	81
Highly Fractured D.G. with water	✓	87	120	33
Total depth: 120 Feet				

Date started May 4, 1987
Date completed May 6, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well with Clean Water to remove mud & gravel pack			
Developed with 250 PSI For 2 hours to Clean			

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter 12¾ to 60' inches Total depth 120 feet
11¼ inches
..... inches
Casing record 8 5/8"
Weight per foot ..... Thickness .188

Diameter	From	To
5 5/8 inches	+2 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 57 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 57 feet to 120 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3/32 x 3½
From 95 feet to 115 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 40 feet below land surface
Flow 50 G.P.M. ..... P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A&H Pump Co. Contractor
Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor

Nevada contractor's license number issued by the State Contractor's Board 23795

Nevada contractor's driller's number issued by the Division of Water Resources .....

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472

Signed [signature]
By driller performing actual drilling on site or contractor

Date May 6, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627