WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28466
Permit No.
Basin 89 - WASHOE VL

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 886

1. OWNER Bell Construction
MAILING ADDRESS 1640 Wagonwheel dr Carson City, Nev 89701
ADDRESS AT WELL LOCATION Lot #7 22 Bellvue

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 16 N/S R. 19 E. Washoe County
PERMIT NO. W City (Issued by Water Resources) | Parcel No. | Lathrop Ranch Estates (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/blow sand		0	5	5
		5		
Sand, fractured L.C. & gravels		5	92	87
Fractured Granite with water	✓	92	110	18
T.D. 110 FT				

Date started May 1, 1987
Date completed May 4, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well with Clean H2O to remove drill mud & gravel pack			
25 GPM from 100'			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11 3/4 to 60 inches, 9 7/8 inches, inches, Total depth 140 feet
Casing record 6 5/8 O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 60 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 60 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 1/16 x 3 1/2
From 84 feet to 104 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 2 feet below land surface
Flow 25+ G.P.M. P.S.I.
Water temperature 60.1 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H & A Pump Co
Address 5th & Hwy 50 Carson City NV 89701 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7345
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1474
Signed Clinton Bell (By driller performing actual drilling on site or contractor)
Date May 5, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (01-62)