WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28475
Permit No.
Basin 8-101

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8721

1. OWNER Richard L. Luttrell
MAILING ADDRESS 7815 Curry Rd. Fallon, Nv. 89406
ADDRESS AT WELL LOCATION SAME AS OWNER

2. LOCATION NE ¼ NE ¼ Sec. 2 T. 17 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Over burden | 0 | 0 | 1 | 1 |
| Clay, Brown | 0 | 1 | 25 | 24 |
| Clay, Gray | 0 | 25 | 26 | 1 |
| Clay, Light Brown | 0 | 26 | 45 | 19 |
| Clay & Sand mixed, Gray | 0 | 45 | 50 | 5 |
| " " " " " | | | | |
| Water Black | 23 | 50 | 75 | 25 |
| Course, Sand, Red, | | | | |
| whites + Grays | 3 | 75 | 77 | 2 |

Date started 5-13, 1987
Date completed 5-14, 1987

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| 3600 | 25 | 15 | 67 |
| Set pump at | | 30' | |
| Do not pump over 25 gpm | | | |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 6 inches Total depth 77 feet
..... inches
..... inches
Casing record 79'
Weight per foot 17.02 Thickness .250

| Diameter | From | To |
|---|---|---|
| 6 inches | +2' feet | 77 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Neat
Depth of seal 25 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 76 feet to 77 feet

Perforations:
Type perforation Torch
Size perforation 5/32 x 4"
From 74 feet to 77 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 3 feet below land surface
Flow — G.P.M. ..... P.S.I.
Water temperature Cold °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water-Rite Well Drilling (Contractor)
Address P.O. Box 883 Fallon, Nv. 89406 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0023978
Nevada contractor's driller's number issued by the Division of Water Resources 1473
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1473
Signed Gerald A. Olson (By driller performing actual drilling on site or contractor)
Date 5-14-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627