



CORRECTED COPY
WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 7496

PRINT OR TYPE ONLY

1. OWNER William & June Ellison ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 1432 _____
Elko, NV 89801 _____
 2. LOCATION SW 1/4 NE 1/4 Sec. 15 T. 32 N/S R. 55 E Elko County _____
 PERMIT NO. _____ Lot 2 Block 10 Unit 1 Lucky Nugget Ranches _____
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0'	5'	5'
Gravel		5'	25'	20'
Gravel & Clay		25'	38'	13'
Fine gravel w/clay		38'	55'	17'
Sandstone & clay		55'	60'	5'
Fine gravel w/some clay		60'	140'	80'
Clay w/some gravel		140'	160'	20'
Fine gravel		160'	180'	15'
Clay w/some gravel		180'	183'	8'
First water at about 60'				
Installed a Sears 3 HP pump at about 160' using polypropalene 1 1/2" pipe. Installed a 1 1/2" x 1 1/2" pitless adapter at 4 ft. Installed a Harvard water tite well cap.				

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 183 feet

Casing record _____
 Weight per foot _____ Thickness .156

Diameter	From	To
6-5/8 o.d. inches	+2 feet	131 feet
6-5/8 o.d. inches	15.1 feet	173 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement
 Depth of seal 46 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 183 feet

Perforations:
 Type perforation Machine slots
 Size perforation 1/8 inch
 From 131 feet to 15.1 feet
 From 173 feet to 183 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started June 8 1987
 Date completed June 10 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blow Test	20-25		

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 35 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada contractor's driller's number issued by the Division of Water Resources 1166
 Nevada driller's license number issued by the Division of Water Resources 1166
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 6-19-87