WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28508
Permit No.
Basin 6-88

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8842

1. OWNER Choddick
MAILING ADDRESS 13504 Mick Circle
Reno Nev

ADDRESS AT WELL LOCATION Lot 267 Unit 2
5465 Golden rod
Callahan Ranch Area

2. LOCATION SE ¼ NW ¼ Sec. 32 T. 17 N S R. 19 E Washoe County

PERMIT NO. WCT4003016 (Issued by Water Resources) | 45-532-06 (Parcel No.) | Galena Terrace (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, Soil w. large boulders		0	7	7
Small to large boulders with sand and small gravels		7	140	133
First water at 113 Ft with small increase in volume to 140 FT	✓			
Total depth 140'				

Date started June 15, 1987
Date completed June 18, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Developed well to remove drill mud and to gravel pack using fresh water			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11" to 60' inches Total depth 140 feet
..... inches
..... inches
Casing record 6 5/8 O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete Redimix
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation Factory Mill slot
Size perforation 3/32 x 3 1/2
From 114 feet to 134 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 feet below land surface
Flow 15+ G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H Pump Co (Contractor)
Address 5331 Hwy 50E Unit 3 C. City (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23295
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6/22/87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627