WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28510
Permit No.
Basin WASHOE V. - 89 I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8997

1. OWNER John Martin
MAILING ADDRESS 1870 Slide View Court Carson City Nev 89701
ADDRESS AT WELL LOCATION 1870 Slide View Court Carson City Nev 89701

2. LOCATION NW ¼ NW ¼ Sec. 31 T. 17 N/S R. 20 E. WASHOE County
PERMIT NO. W Cty 003017 (Issued by Water Resources) 50-060-13 (Parcel No.) Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/ sand		0	7	7
Fine Sand with Silt with Water	✓	7	80	73
Course Sand w/ silt	✓	80	87	7
Course to fine Sand w/ silt	✓	87	113	26
Course to Med Course Sand & Silt	✓	113	139	26
Fine Sand w/ Silt	✓	139	145	6
Note: placed 10' pea gravel in casing to stop heaving sand & silt				
T.D. 145'				

Date started 6/22, 1987
Date completed 6/23, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed well with clean water to remove drill mud & to gravel pack. Cemented the right tremi from 96' to surface			

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 11 3/4 to 60 inches Total depth 145 feet
Casing record 6 5/8" O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	145 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 96 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 96 feet to 145 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 1/16" x 3 1/2"
From 115 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level Ground level feet below land surface
Flow 15+ G.P.M. ..... P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name A & H Pump Co (Contractor)
Address 535 Hwy 50E #3 Carson City, Nev (Contractor)
Nevada contractor's license number 23295
Nevada contractor's drillers number
Nevada driller's license number 1472 (Actual Driller)
Signed [signature] (Contractor)
Date 6/25/87

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434