


Log No. 2852

Permit No. _____

Basin 6-9-1



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 8554

1. OWNER TERRY SCOTT ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 15 Zane Gray 660 Dog Valley Road
Reno, Nevada 895233 Verdi, Nevada 89439
 2. LOCATION SW 1/4 SE 1/4 Sec. 7 T. 19N. N/S R. 18 E Washoe County
 PERMIT NO. _____ Verdi
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Some top soil with gravels & boulders		0	2	2
Brown clay with gravels		2	12	10
Gray clay		12	36	24
Gray rock		36	41	5
Soft zone		41	44	3
Med. soft gray rock		44	95	51
Fracture (3-5 GPM app)	X	95	97	2
Hard gray rock		97	110	13
Soft to med. streaks of hardend gray rock		110	192	82
Fracture (NO WATER)		192	193	1
Hard & soft gray rock		193	319	126
Fracture (2-3 GGPM app)	X	319	321	2
Med. hard gray rock		321	361	40
Soft gray rock		361	381	20
Fracture rock	X	381	392	11
Gray rock		392	400	8

8. WELL CONSTRUCTION
 Diameter 10 inches Total depth 400 feet
6 inches
6 inches
 Casing record 400 ft. steel casing installed.
 Weight per foot _____ Thickness .156

Diameter	From	To
<u>6 5/8"</u> inches	<u>0</u> feet	<u>400</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type cement
 Depth of seal 51 feet
 Gravel packed: Yes No
 Gravel packed from 51 feet to 400 feet
 Perforations:
 Type perforation factory sawed slot
 Size perforation 3/32 x 3 x 6 around
 From 340 feet to 400 feet
 From _____ feet to _____ feet

Date started 5-13-87, 19____
 Date completed 5-15-87, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 20 feet below land surface
 Flow 50± G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Contractor
 Address P.O. Box 12370, Reno, NV 89510
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board XXXXXX 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date May 22, 1987