

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8717

1. OWNER Mike Mouliot ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 48 High St. 9800 N. Virginia
Reno, Nv 89502

2. LOCATION SW 1/4 NW 1/4 Sec 8 T 20 N/S R 19 E Washoe County
 PERMIT NO. 82-101-29

Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sticky brown clay		0	32	32
Brown clay with yellow green brown white & purple volcanic sands		32	123	91
green brown yellow purple white volcanic rock		123	304	181
T.D. <u>304'</u>				

Log # 28756 is pluging report

8. 10" - 50' WELL CONSTRUCTION

Diameter 8 1/2 inches Total depth 293 feet
6 1/2 inches
6 5/8 inches

Casing record 6 5/8
 Weight per foot 10.78 & 12.52 Thickness .156 & .188

Diameter	From	To
<u>6 5/8</u> inches	<u>+2</u> feet	<u>159</u> feet
<u>5</u> inches	<u>133</u> feet	<u>293</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type neat cement
 Depth of seal 52' feet
 Gravel packed: Yes No
 Gravel packed from 52 feet to 157 feet

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3"
 From 137 feet to 157 feet
 From 273 feet to 293 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

9. WATER LEVEL

Static water level 120 feet below land surface
 Flow 20+ G.P.M. P.S.I.
 Water temperature cold °F Quality _____

Date started 5/22, 19____
 Date completed 5/27, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blew with air to clean and develop.			
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling and Well Service, Inc.
 Address 2255 Glendale Ave. Sparks, Nv 89431
 Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada contractor's driller's number 1132
 issued by the Division of Water Resources
 Nevada driller's license number issued by the 1511
 Division of Water Resources, the on-site driller
 Signed Roger M. Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 6/1/87

STATE ENGINEERS OFFICE
RECEIVED

87 JUN -3 A9:51

3-10-87