



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8760

1. OWNER BILL HARVEY/ROBERT KELLEY ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 9479 Wigwam 690 Alaska  
Reno, Nevada 89506 Reno, Nevada 89506  
 2. LOCATION SW  $\frac{1}{4}$  SE  $\frac{1}{4}$  Sec. 23 T. 21 N/S R. 19 E. Washoe County  
 PERMIT NO. 80-274-04 Lemmon Valley  
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>XXXXXX</del> Top soil		0	1	1
Brown sandy clay		1	4	3
Brown sand		4	5	1
Brown clay		5	39	34
Soft zone		39	42	3
Brown clay		42	46	4
Soft sandy brown clay		46	92	46
Med soft sand	X	92	96	4
Brown clay		96	101	5
Soft zone, coarse sand	X	101	126	25
Brown clay		126	128	2
Coarse sands	X	128	132	4
Weathered granite with clay streaks		132	135	3

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 135 feet  
6 inches  
         inches

Casing record 135' steel casing installed  
 Weight per foot          Thickness .156

Diameter	From	To
<u>6.5/8</u> inches	<u>0</u> feet	<u>135</u> feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes  No  Type cement  
 Depth of seal 53 feet  
 Gravel packed: Yes  No   
 Gravel packed from 53 feet to 135 feet

Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 100 feet to 130 feet  
 From          feet to          feet  
 From          feet to          feet  
 From          feet to          feet  
 From          feet to          feet

Date started 6-3-87, 19      
 Date completed 6-3-87, 19    

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M.          Draw down          feet          hours  
 G.P.M.          Draw down          feet          hours  
 G.P.M.          Draw down          feet          hours

9. WATER LEVEL

Static water level 59 feet below land surface  
 Flow 39 G.P.M.          P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc.  
 Address P.O. Box 12370, Reno, NV 89510  
Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada contractor's driller's number issued by the Division of Water Resources 908  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed Wayne P. Johnson  
By driller performing actual drilling on site or contractor  
 Date June 3, 1987