



WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6459

1. OWNER ROBERT SPURLOCK ADDRESS AT WELL LOCATION _____
MAILING ADDRESS 950 SOUTH ROCK BLVD. 3550 GREEN AVENUE
SPARKS, NEVADA 89431 SILVER SPRINGS, NEVADA

2. LOCATION 1/4 N 1/4 Sec 5 T 17 N 25 E LYON County _____
PERMIT NO. _____ # 3 LAKE VIEW Subdivision Name _____
Issued by Water Resources Parcel No. _____

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
coarse sand & fine gravel		0	10	10
clay		10	22	12
coarse sand & fine gravel		22	30	8
thin layers coarse sand & clay		30	105	75
clean fine to medium gravel		105	136	21
gray sandy clay w/sand layers		136	157	11
fine to medium gravel		157	192	35
brown clay		192	196	4
coarse sand		196	207	11
brown & gray clay		207	222	15
coarse sand to fine gravel	XX	222	240	8
coarse sand, fine to medium gravel	XX	240	260	20
fine gravel to coarse gravel	XX	260	280	20
fine gravel to medium gravel	XX	280	291	11
clay		291	300	9

8. WELL CONSTRUCTION

Diameter 12 1/2 inches Total depth 300 feet

Casing record 8-5/8" O.D. x .188 wall

Weight per foot 16.94 Thickness _____

Diameter	From	To
<u>8</u> inches	<u>+1</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement grout

Depth of seal 50 feet

Gravel packed: Yes No

Gravel packed from 50 feet to 300 feet

Chevreux 1/8" x 1/4" quartz pebbles

Perforations:

Type perforation Milled - 8-5/8" O.D. x .250 wall

Size perforation 3" x 1/8" double standard

From 220 feet to 300 feet

From _____ feet to _____ feet

Date started MAY 27, 1987

Date completed MAY 29, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	300-400	10-20	4
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL

Static water level 55 feet below land surface

Flow _____ G.P.M. _____ P.S.I.

Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES SARGENT IRRIGATION, INC. Contractor

Address 9955 NORTH VIRGINIA STREET RENO, NV Contractor 89506

Nevada contractor's license number issued by the State Contractor's Board 21246

Nevada contractor's driller's number issued by the Division of Water Resources 1391

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482

Signed Charles Sargent By driller performing actual drilling on site or contractor

Date JUNE 2, 1987

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours

G.P.M. _____ Draw down _____ feet _____ hours