WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28545
Permit No.
Basin 8-103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8213

1. OWNER Pallino Ray, Ernest (H. Gordo)
MAILING ADDRESS Carson City, Nevada
ADDRESS AT WELL LOCATION 1877 Ruby Lane, Carson City, Nevada

2. LOCATION SE ¼ NE ¼ Sec. 4 T. 15 N/S R. 20 E/W Carson City County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☑ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden w/boulders		0	5	5
Cemented gravel w/clay, yellow to tan coloring		5	186	181
Hard to very hard sandstone, fine grained, greyish brown to grey		186	257	71
Brown Medium to coarse sand. Stone w/fractures at water at 251		257	320	63
Total depth 320 feet				

Date started June 5, 19 87
Date completed June 11, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Unknown	Well	for 24 hours	
each	2.5	per hr	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 11" to 60' 6¾ inches Total depth 320 feet
..... inches
..... inches
Casing record 6 5/8 O.D.
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	42 feet	320 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 58 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 58 feet to 320 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 3/32 x 3 1/2
From 295 feet to 315 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 225 feet below land surface
Flow 15 G.P.M. ..... P.S.I.
Water temperature 65 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AE H Pump Co (Contractor)
Address 455 Hungry Hole #3 C.C., Nv (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 23595
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 14,[illegible]
Signed Warren Butts (By driller performing actual drilling on site or contractor)
Date 6/14/87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627