

OFFICE USE ONLY  
 Log No. 28574  
 Permit No. \_\_\_\_\_  
 Basin 230

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 4754

PRINT OR TYPE ONLY

1. OWNER Richard Records ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NW 1/4 Sec 7 T. 17.5 N/S R. 45 E Nye County  
 PERMIT NO. \_\_\_\_\_ Parcel No. 3 Subdivision Name Lot 8

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material       | Water Strata | From | To  | Thick-ness |
|----------------|--------------|------|-----|------------|
| Sand           |              | 0    | 3   | 3          |
| Sand & gravel  |              | 3    | 29  | 26         |
| Caliche        |              | 29   | 31  | 2          |
| Sand           |              | 31   | 42  | 11         |
| Coarsened Sand |              | 42   | 61  | 19         |
| Sand & gravel  | WB           | 61   | 116 | 55         |

8. WELL CONSTRUCTION  
 Diameter 12 1/4 inches Total depth 116 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 116 Ft. 8 3/8 inch  
 Weight per foot 14.1 Thickness 1.56  
 Diameter From To  
8 7/8 inches 0 feet 116 feet  
 \_\_\_\_\_ inches \_\_\_\_\_ feet \_\_\_\_\_ feet  
 Surface seal: Yes  No  Type Concrete  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 116 feet  
 Perforations:  
 Type perforation torch  
 Size perforation 1/8 inch by 6 inch  
 From 6.0 feet to 116 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 JUN 08 1987  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4-14, 1987  
 Date completed 4-15, 1987

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

9. WATER LEVEL  
 Static water level 60 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name S.H. Drilling Contractor  
 Address HCR Box 70706 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22059  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1426  
 Signed Steve Mount  
 By driller performing actual drilling on site or contractor  
 Date 5/31-87

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours