


OFFICE USE ONLY  
 Log No. 28585  
 Permit No. \_\_\_\_\_  
 Basin 162



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 820

1. OWNER F. Marvin Livingston ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump Nevada 89041

2. LOCATION NE 1/4 SW 1/4 Sec. 34 T. 19 S. N/S R. 53 E. Myro County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Unit 1 Gerald Martin Subdivision Subdivision Name \_\_\_\_\_  
 Issued by Water Resources | Parcel No. \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Sandy Clay		4	35	31
Grey Clay		35	55	20
Clay with Gravel		55	78	23
Soft Brown Clay		78	122	44
Hard Shale		122	128	4
Brown Clay	x	128	146	18
Tough Clay		146	155	9
Brown Clay with Large Gravel	x	155	188	33
Brown Clay	x	188	200	18

RECEIVED

MAY 15 1987

Div. of Water Resources  
 Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION  
 Diameter 12 inches Total depth 200 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 200 Ft. of 8 in casing  
 Weight per foot 18 lbs. Thickness .188  

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type concrete  
 Depth of seal 105 feet  
 Gravel packed: Yes  No   
 Gravel packed from 105 feet to 200 feet

Perforations:  
 Type perforation Torch Cut  
 Size perforation 1/2 in width 8 in long  
 From 140 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started March 20, 1987  
 Date completed March 20, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. 20 gals. Draw down 4 feet 1/2 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 73 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Charles Nyberg Contractor  
 Address St. Rt. Box 36525 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 7484  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725  
 Signed Charles Nyberg By driller performing actual drilling on site or contractor  
 Date May 14, 1987