



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 4841

1. OWNER Clyde Raper ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Pahrump, Nevada 89041

2. LOCATION 1E 1/4 SE 1/4 Sec. 15 T. 20-S N/S R. 53 E. 1/2 County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ Parcel No. 5 Subdivision Name Bolling Green Acres

3. TYPE OF WORK		4. PROPOSED USE		5. TYPE WELL	
New Well <input checked="" type="checkbox"/>	Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/>	Irrigation <input type="checkbox"/>	Cable <input checked="" type="checkbox"/>	Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/>	Other <input type="checkbox"/>	Municipal <input type="checkbox"/>	Industrial <input type="checkbox"/>	Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Surface		0	4	4
Broken Caliche		4	26	22
Clay with Small Gravel		26	40	14
Caliche		40	44	4
Brown Clay		44	116	72
Hard Lime	x	116	122	6
Brown Clay with Small Gravel	x	122	162	40
Hard Lime		162	174	12
Clay with Rocks	x	174	200	26

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 200 feet

Casing record 200 ft. of 8 in casing

Weight per foot 18 lbs. Thickness 188

Diameter	From	To
<u>12</u> inches	<u>0</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type concrete

Depth of seal 50 feet

Gravel packed: Yes  No

Gravel packed from 50 feet to 200 feet

Perforations:

Type perforation Torch Cut

Size perforation 1/2 in width 8 in long

From 120 feet to 200 feet

RECEIVED  
 MAY 15 1987

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started April 20, 1987  
 Date completed April 20, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 36 feet below land surface

Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.

Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Charles Nyberg Contractor

Address St. Rt. Box 36525 Contractor

Nevada contractor's license number 7484 issued by the State Contractor's Board

Nevada contractor's driller's number \_\_\_\_\_ issued by the Division of Water Resources

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 725

Signed Charles Nyberg  
 By driller performing actual drilling on site or contractor

Date May 14, 1987

BAILER TEST

G.P.M. 20 gals. Draw down 4 feet 1/2 hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours