

Log No. 28650

Permit No. 212
 Basin 212

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. _____

1. OWNER SHAWBROT INC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____

2. LOCATION NW 1/4 SW 1/4 Sec 8 T. 22 N/S R. 02 E CLARK County

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock Other
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>ROCKS + Clay</u>		<u>0</u>	<u>50</u>	<u>50</u>
<u>Caliche</u>		<u>50</u>	<u>58</u>	<u>8</u>
<u>Clay + Rocks</u>		<u>58</u>	<u>210</u>	<u>152</u>
<u>Clay</u>		<u>210</u>	<u>252</u>	<u>42</u>
<u>Clay w/ STREAK OF GRAVEL</u>		<u>252</u>	<u>520</u>	<u>268</u>
<u>Red Clay</u>		<u>520</u>	<u>685</u>	<u>165</u>

CMT Test Hole
FROM 90' TO SURFACE

8. WELL CONSTRUCTION

Diameter hole 7 7/8 inches Total depth 685 feet
 Casing record _____
 Weight per foot _____ Thickness _____
 Diameter From To
 _____ inches _____ feet _____ feet
 Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet
 Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

RECEIVED
MAY 14 1987

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 4-6- 1987
 Date completed 4-13- 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 142 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lee R. Thomas Contractor
 Address 5965 N. MANVERICK Contractor
 Nevada contractor's license number 10831
 Nevada contractor's drillers number 623
 Nevada driller's license number 623 Actual Driller
 Signed Lee R. Thomas Contractor
 Date 5-7-87

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours