


OFFICE USE ONLY
Log No. 28655
Permit No. 163
Basin 163



WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 4528

PRINT OR TYPE ONLY

1. OWNER RICH BALE ADDRESS AT WELL LOCATION 1450 E JADE
MAILING ADDRESS Box 409 HCR 70 JEAN, NEV. 89019

2. LOCATION SE $\frac{1}{4}$ NW $\frac{1}{4}$ Sec 4 T. 2S R. 5E County
PERMIT NO. 219-04-201-004 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input checked="" type="checkbox"/> Rotary <input type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Rocky ALLUVIAL CLAY		0	79	79
SANDY CLAY CONS.		79	84	5
LOOSE ROCK CLAY	WTR89	84	88	4
LOOSE ROCK CLAY		88	102	24
LOOSE ROCK CLAY	WTR	102	106	4
LOOSE ROCK CLAY		106	113	7
ROCK & CLAY		113	123	10
SAND & ROCK CLAY & ROCK	WTR	123	128	5
SAND & ROCK CLAY & ROCK		128	136	8
SAND & ROCK CLAY & ROCK	WTR	136	148	12
SAND & ROCK CLAY & ROCK		148	155	7

8. WELL CONSTRUCTION

Diameter 14 inches Total depth 155 feet

Casing record STEEL
Weight per foot 12.5 Thickness .156

Diameter	From	To
<u>8 7/8</u> inches	<u>0</u> feet	<u>155</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 80 feet to 155 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4"
From 125 feet to 155 feet

RECEIVED
MAY 18 1987

Div. of Water Resources
Branch Office - Las Vegas, NV

Date started APRIL 24 19 87
Date completed MAY 12 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 79 feet below land surface
Flow _____ G.P.M. _____ P.S.I.
Water temperature 78 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC Contractor
Address 1701 W CHARLSTON LN NEV 89102 Contractor
Nevada contractor's license number issued by the State Contractor's Board 1352020303
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spurlock
By driller performing actual drilling on site or contractor
Date April 15-87

BAILER TEST

G.P.M. 30 Draw down 21 feet 1 hours
G.P.M. _____ Draw down _____ feet _____ hours
G.P.M. _____ Draw down _____ feet _____ hours