

OFFICE USE ONLY
 Log No. 286672
 Permit No. 50306/40498
 Basin. 61 - Boulder Flat

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO.

1. OWNER BARRICK GOLDSRIKE MINES INC. ADDRESS AT WELL LOCATION GOLD STRIKE MINE - NORTHWEST OF CARLIN
 MAILING ADDRESS P. O. BOX 29
ELKO, NEVADA 89801

2. LOCATION SW 1/4 NW 1/4 Sec. 29 T. 36 N. R. 50 E. EUREKA County

PERMIT NO. 48498 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input checked="" type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
gravel		0	65	65
clay w/some sand		65	250	185
clay		250	260	10
sand		260	272	12
clay & sand	XX	272	435	163
sand	XX	435	442	7
clay & sand	XX	442	496	54
sand	XX	496	512	16
clay & sand	XX	512	578	66
black rock & clay	XX	578	803	225
fractured areas				
Electric well log				
by Sargent Irrigation Company				

8. WELL CONSTRUCTION

Diameter 17 1/2 inches Total depth 720 feet
 Casing record 12-3/4" O.D. x 250 wall
 Weight per foot 33.04 Thickness
 Diameter 12 inches From +1 feet To 720 feet
 Surface seal: Yes No Type cement grout
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from 60 feet to 720 feet
Chevreaux quartz pebbles 1/8" x 1/4"
 Perforations:
 Type perforation single perf. 3" x 1/8"
 Size perforation shutter screen 1 1/2" x 1/8"
 From shutter 160 feet to 190 feet
 From slot 190 feet to 240 feet
 From shutter 240 feet to 290 feet
 From slot 290 feet to 500 feet
 From shutter 500 feet to 580 feet
 From slot 580 feet to 620 feet
 From shutter 620 feet to 700 feet
 9. WATER LEVEL
 Static water level _____ feet below land surface
 Flow 1 G.P.M. P.S.I.
 Water temperature cold °F Quality good

Date started February 20, 1987
 Date completed March 20, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	300	97	1
	519	210 1/2	1
	600	295 1/2	1
	500	428	24

BAILER TEST
 G.P.M. Draw down _____ feet _____ hours
 G.P.M. Draw down _____ feet _____ hours
 G.P.M. Draw down _____ feet _____ hours

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CHARLES SARGENT IRRIGATION, INC.
 Contractor
 Address 9955 NORTH VIRGINIA STREET RENO, NV 89506
 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 21246
 Nevada contractor's driller's number issued by the Division of Water Resources 1391
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 1388
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date APRIL 27, 1987