WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28672
Permit No. 41396
Basin 13-212 LVAB
In Book
NOTICE OF INTENT NO. 1258

PRINT OR TYPE ONLY

OWNER Joseph Jerry
MAILING ADDRESS
ADDRESS AT WELL LOCATION

2. LOCATION NW ¼ SW ¼ Sec. 33 T 22s N/S R 61 E Clark County
PERMIT NO. 41396 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE Quasi: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & gravel		0	23	23
pea gravel & clay		23	147	124
pea gravel & red clay		147	162	15
red clay		162	204	42
cemented conglom	X	204	265	61
cemented conglom		265	360	105
red clay		360	374	14
cemented conglom		374	450	86

RECEIVED
MAY 11 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started May 1, 19 84
Date completed May 7, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air	50	?	1

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 450 feet
Casing record 8-5/8"
Weight per foot 16.94 Thickness .156

Diameter	From	To
inches	0 feet	450 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 4 4 around
From 220 feet to 450 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 173 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling Inc. (Contractor)
Address 4847 So. VAlley View (Contractor)
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1376 (Actual Driller)
Signed [signature] (Contractor)
Date May 9, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28672
Permit No. ~~41396~~ 55526
Basin 212

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1258

OWNER SIDDALL WATER ASSOCIATION ~~Joseph Jerry~~

ADDRESS AT WELL LOCATION

MAILING ADDRESS

2. LOCATION NW ¼ SW ¼ Sec. 33 T 22s N/S R. 61 E Clark County

PERMIT NO. ~~41396~~ 55526 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand & gravel		0	23	23
pea gravel & clay		23	147	124
pea gravel & red clay		147	162	15
red clay		162	204	42
cemented conglom	X	204	265	61
cemented conglom		265	360	105
red clay		360	374	14
cemented conglom		374	450	86

RECEIVED
MAY 11 1984
Div. of Water Resources
Branch Office — Las Vegas, Nev.

Date started May 1, 1984
Date completed May 7, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air	50	?	1

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 12 inches Total depth 450 feet
Casing record 8-5/8"
Weight per foot 16.94 Thickness .156

Diameter	From	To
inches	0 feet	450 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 50' feet
Gravel packed: Yes ☐ No ☒
Gravel packed from feet to feet

Perforations:
Type perforation Torch
Size perforation 1/8 x 4 4 around
From 220 feet to 450 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 173 feet below land surface
Flow G.P.M. P.S.I.
Water temperature ° F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Allen Drilling Inc. (Contractor)
Address 4847 So. VAlley View (Contractor)
Nevada contractor's license number 018917
Nevada contractor's drillers number 1301
Nevada driller's license number 1376 (Actual Driller)
Signed [signature] (Contractor)
Date May 9, 1984

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434