1

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28681
Permit No. 46719
Basin 2-29

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER Connecticut General Life (INA.)
MAILING ADDRESS c/o Donna Hesterson Co
1255 E. Plumb Ln. Suite 145 Reno Nv. 89502

ADDRESS AT WELL LOCATION

2. LOCATION SE ¼ SW ¼ Sec. 22 T. 44 N/8 R. 31 E. HUMBOLDT County

PERMIT NO. 46719 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	10	10
Clay		10	15	5
Sand + gravel		15	95	80
Sand + clay		95	110	15
Gravel		110	117	7
Sand		117	135	18
Lava Rock		135	140	5
Soft brown clay		140	145	5
Lava boulders		145	171	24
Hard Clay		171	180	9
Granite sand		180	255	75
Soft brown clay		255	265	10
Sand + clay		265	290	25
Sand + gravel		290	327	37
Sand gravel + clay		327	400	73
Sand + gravel		400	405	5
Sandy clay		405	450	45

Date started 2-15-87, 19
Date completed 3-5-87, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	1400	160	8 hrs

BAILER TEST

G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION

Diameter 27 inches Total depth 450 feet
inches
inches

Casing record
Weight per foot Thickness 1/4"

Diameter	From	To
16 inches	0 feet	450 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type concrete
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 450 feet

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL

Static water level 54 feet below land surface
Flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Armstrong Bros
Contractor

Address
Contractor

Nevada contractor's license number issued by the State Contractor's Board

Nevada contractor's driller's number issued by the Division of Water Resources 1505

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1506

Signed Roger Armstrong
By driller performing actual drilling on site or contractor

Date 5-11-87

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627