WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28713
Permit No. 50925
Basin 138-GRASS V
I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 7929

1. OWNER NA Degerstrome
MAILING ADDRESS Box 29 Crecent Valley Nv.
ADDRESS AT WELL LOCATION Lander Co

2. LOCATION ~~SE~~ NW ¼ NW ¼ Sec. ~~20~~ 19 T. ~~25~~ 27 N S R. 47 E Lander County
PERMIT NO. ~~50119~~ 50925 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☑ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand Gravel & Bolders		0	25	25
"		25	50	25
"		50	75	25
"		75	100	25
Sand Gravel Clay		100	125	25
Sand Gravel Lg Bolders		125	150	25
Sand Gravel Bolders		150	175	25
"		175	200	25
"		200	225	25
"		225	250	25
"		250	275	25
"		275	300	25
"		300	325	25
Sand Gravel & Bolders		325	350	25
"		350	375	25
Sand Gravel & Bolders		375	400	25
"		400	425	25
"		425	450	25
"		450	500	50
Sand & Fine Gravel		500	550	150
Green Clay		550	650	100
Clean Gravel		650	675	25
Clean Gravel & Bolders		675	750	75
"		750	775	25

Date started March, 1987
Date completed May 3, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 8 inches Total depth 775 feet
Casing record
Weight per foot ..... Thickness

Diameter	From	To
8 inches	0 feet	775 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type
Depth of seal 50 ft feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation Dawant
Size perforation
From 625 feet to 775 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60 feet below land surface
Flow Good G.P.M. ..... P.S.I.
Water temperature Cold Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge. Norm Parsons
Name Keith K. Kuleichek (Contractor)
Address 4062 W. Wenn Blvd (Contractor)
Wennemucca
Nevada contractor's license number 24091
Nevada contractor's drillers number
Nevada driller's license number 1454 (Actual Driller)
Signed Circle K. Drilling & Pump Co (Contractor)
Date 5-28-87

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434