WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
**DIVISION OF WATER RESOURCES**

# WELL DRILLER'S REPORT

**Please complete this form in its entirety**

OFFICE USE ONLY
Log No. 28721
Permit No.
Basin 2-105

I

**PRINT OR TYPE ONLY**

NOTICE OF INTENT NO. 6453

1. OWNER BENTLY NEVADA CORPORATION
MAILING ADDRESS 1617 WATER STREET
MINDEN, NEVADA 89423

ADDRESS AT WELL LOCATION
MONITOR WELL 8C - WITT PROPERTY
Johnson Lane Area - Northeast Minden Airport

2. LOCATION SE ¼ NW ¼ Sec. 8 T. 13 N/S R. 20 E. DOUGLAS County
PERMIT NO. Waiver 3/9/87 (Issued by Water Resources) Parcel No. Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. ZONE C PROPOSED USE MONITOR WELL
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sand, gravel & clay | | | | |
| layered | | 0 | 62 | 62 |
| sandy clay | | 62 | 119 | 57 |
| sand w/trace clay | | 119 | 130 | 11 |

Date started MAY 2, 19 87
Date completed MAY 7, 19 87

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| air lift | 25 | | ½ |

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 130 feet
9-7/8 inches
inches
Casing record 8-5/8"O.D.x.188 wall/ 4½"O.D.x.156wall
Weight per foot 16.94 / 7.24 Thickness

| Diameter | From | To |
|---|---|---|
| 12 - 8 inches | +1 feet | 90 feet |
| inches | feet | feet |
| 9 - 4 inches | +1 feet | 130 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type cement-bentonite grout slurry
Depth of seal 0 - 90 & 0 - 110 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 110 feet to 130 feet
Monterey #3 filter sand equivalent 115-130
Monterey #20 fine mesh sand 110-115
Perforations:
Type perforation Johnson Well Screen stainless
Size perforation steel / .020" slot / std wgt
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 2 feet below land surface
Flow G.P.M. P.S.I.
Water temperature cold °F Quality AS PER ANALYSIS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CHARLES SARGENT IRRIGATION, INC. (Contractor)
Address 9955 NO. VIRGINIA STREET RENO, NV 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1392
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1491
Signed [signature] (By driller performing actual drilling on site or contractor)
Date MAY 11, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627