

WELL DRILLER'S REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 6454

PRINT OR TYPE ONLY

1. OWNER BENTLY NEVADA CORPORATION
 MAILING ADDRESS 1617 WATER STREET
MINDEN, NEVADA 89423

ADDRESS AT WELL LOCATION
Monitor Well 8D - Witt Property
Johnson Lane Area - Northeast Minden Airport

2. LOCATION SE 1/4 NW 1/4 Sec 8 T 13 N S R. 20 E DOUGLAS County
 PERMIT NO. WALVER 3/9/87
Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. ZONE D
 Domestic
 Municipal

PROPOSED USE Monitor Well
 Irrigation Test
 Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand, gravel & clay layered		0	62	62
sandy clay		62	119	57
sand w/trace of clay		119	160	41
clay w/trace of sand		160	193	33
clay & layered gravel		193	210	17
sand		210	220	10
gravel		220	225	5
hard clay		225	230	5
<i>plugged by well log 1/4 251</i>				
Electric Geophysical Log By Geo-Hydro Data				

8. WELL CONSTRUCTION

Diameter 12 1/4 inches Total depth 230 feet
9-7/8 inches
9-7/8 inches

Casing record 8-5/8" O.D. X .188 wall / 4 1/2" O.D. .156" wal
 Weight per foot 16.94 / 7.24 Thickness _____

Diameter	From	To
12 - 8 inches	+1 feet	197 feet
_____ inches	_____ feet	_____ feet
9 - 4 inches	+1 feet	230 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type cement-bentonite grou
slurry
 Depth of seal 0 - 197 & 0 - 210 feet

Gravel packed: Yes No
 Gravel packed from 210 feet to 230 feet
 Monterey #3 filter sand equivalent 215-230
 Monterey #20 equivalent fine mesh sand 210-215
 Perforations: _____
 Type perforation Johnson Well Screen Stainless
 Size perforation steel / .020" slot / std wgt
 From 220 feet to 230 feet
 From _____ feet to _____ feet

Date started April 27, 1987
 Date completed May 2, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	2		1 1/2

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level _____ feet below land surface
 Flow 1 to 2 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality AS PER ANALYSIS

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name CHARLES SARGENT IRRIGATION, INC.
 Contractor
 Address 9955 NO. VIRGINIA STREET RENO, NV 89506
 Contractor

Nevada contractor's license number
 issued by the State Contractor's Board 21246

Nevada contractor's driller's number
 issued by the Division of Water Resources 1391

Nevada driller's license number issued by the
 Division of Water Resources, the on-site driller 1491

Signed Charles Sargent
 By driller performing actual drilling on site of contractor

Date MAY 11, 1987