WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 28753
Permit No.
Basin 8-105

I

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6455

1. OWNER BENTLY NEVADA CORPORATION
MAILING ADDRESS 1617 WATER STREET
MINDEN, NEVADA 89423

ADDRESS AT WELL LOCATION
MONITOR WELL 14C
JOHNSON LANE AREA - NORTHEAST MINDEN AIRPORT

2. LOCATION SW ¼ NW ¼ Sec. 8 T 13 N/S R 20 E DOUGLAS County
PERMIT NO. WAIVER 3/9/87 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
clay with thin sand layers		0	40	40
sand with clay & gravel layers		40	98	58
blue clay		98	108	10
clay & sand		108	120	12
sand with thin clay layers		120	130	10
clean sand		130	140	10
coarse sand		140	150	
Electric Geophysical Log By Geo-Hydro Data				

Date started MAY 18, 1987
Date completed MAY 22, 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
air lift	5		2

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches, 9-7/8 inches, ... inches
Total depth 150 feet
Casing record 8-5/8"O.D.x.188wall/4½"O.D.x.56wall
Weight per foot 16.94 / 7.24 Thickness

Diameter	From	To
12 - 8 inches	+1 feet	110 feet
..... inches	..... feet	..... feet
9 - 4 inches	+1 feet	150 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☒ No ☐ Type cement-bentonite grout slurry
Depth of seal 0-110 & 0-130 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 130 feet to 150 feet
Monterey #3 filter sand equivalent 135-150
Monterey #20 fine mesh sand 130-135
Perforations:
Type perforation ROSCOE MOSS Well Screen
Size perforation stainless steel/.020"slot/std wgt
From 140 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 2.4 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature cold °F Quality AS PER ANALYSIS

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name SARGENT IRRIGATION COMPANY (Contractor)
Address 9955 NO. VIRGINIA ST. RENO, NEVADA 89506 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 21246
Nevada contractor's driller's number issued by the Division of Water Resources 1391
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1491
Signed [signature] (By driller performing actual drilling on site or contractor)
Date JUNE 8, 1987

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627