WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

OFFICE USE ONLY
Log No. 28766
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 8948

1. OWNER Victor Ward
MAILING ADDRESS 2724 Gordon
Minden, Nev
ADDRESS AT WELL LOCATION 2724 Gordon
Minden, Nev

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 14 N/S R. 20 E/W Douglas County
PERMIT NO. (Issued by Water Resources) Parcel No. Johnson Lane Area (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other Replacement ☑

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden, blow sand		0	5	5
Sandy Clay		5	25	20
Fine Sand		25	68	43
Clay		68	70	2
Sand w/gravel small amount of water	✓	70	92	22
Tight, heavy Clay		92	116	24
Gravel with Sand, Water		116	140	24
T.D. 140 ft				
Plugging Log # 28767				
Orig. Well # 12144				

Date started July 3, 19 87
Date completed July 3, 19 87

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Flushed w/ clear water to clear + gravel-pack			
25+ GPM from 110' with air			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 11¼" inches Total depth 140 feet
Casing record 6 5/8"
Weight per foot 11.7 Thickness .156

Diameter	From	To
6 5/8 inches	+2 feet	140 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Concrete
Depth of seal 55 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 55 feet to 140 feet

Perforations:
Type perforation Factory Mill Slot
Size perforation 1/16" x 3½"
From 115 feet to 135 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 30 feet below land surface
Flow 25 G.P.M. P.S.I.
Water temperature Cool ° F. Quality Good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name H+H Pump Co (Contractor)
Address 5551 Harvey Way #E3 Carson City, Nev (Contractor)
Nevada contractor's license number 23275
Nevada contractor's drillers number
Nevada driller's license number 1472
Signed Quinton Betts (Actual Driller) (Contractor)
Date July 6, 1987

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434