



**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8759

1. OWNER LYNN SEMENZA ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 914 Keele Drive 5555 Golden Rod  
Reno, NV 89509 Reno, NV 89511  
 2. LOCATION NW 1/4 NW 1/4 Sec 2 T 17 N R 19 E Washoe County  
 PERMIT NO. 045-533-17 Parcel No. Calahan Ranch Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other  Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top soil with boulders		0	1	1
Brown clay with boulders		1	10	9
Boulder		10	13	3
Brown clay with gravel and boulders		13	68	55
Soft zone NO WATER		68	71	3
Volcanic & granite boulders with brown clay		71	145	74
Soft zone NO WATER		145	149	4
Brown clay		149	155	6
Soft zone		155	161	6
Volcanic & granite boulders with brown clay		161	205	44
Soft zone	X	205	208	3
Soft sandy brown clay		208	230	22
Soft zone	X	230	245	15
Volcanic & granite boulders with brown clay		245	250	5

8. WELL CONSTRUCTION  
 Diameter 10 inches Total depth 250 feet  
6 inches  
 Casing record 250' steel casing installed  
 Weight per foot \_\_\_\_\_ Thickness .156  

Diameter	From	To
<u>6 5/8</u> inches	<u>0</u> feet	<u>250</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 250 feet  
 Perforations:  
 Type perforation factory sawed slot  
 Size perforation 3/32 x 3 x 6 around  
 From 207 feet to 247 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 6-22-87, 19\_\_\_\_  
 Date completed 6-23-87, 19\_\_\_\_

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 153 feet below land surface  
 Flow 30 G.P.M. P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wayne Drilling, Inc. Contractor  
 Address P.O. Box 12370, Reno, Nv 89510 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada contractor's driller's number issued by the Division of Water Resources 908  
 Nevada driller's license number issued by the Division of Water Resources the on site driller 923  
 Signed Jay L. Feldman By driller performing actual drilling on site or contractor  
 Date June 25, 1987