



WELL DRILLERS REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 8312

1. OWNER Dan Robinson ADDRESS AT WELL LOCATION #4 Block 10
 MAILING ADDRESS lot 5

2. LOCATION 9W 1/4 NE 1/4 Sec. 19 T. 35 N/S 86 E. 21ka County _____
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Meadow Valley Ranches

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation
 Municipal Industrial

5. TYPE WELL
 Cable Rotary
 Other AIL

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil</u>		<u>0</u>	<u>3</u>	
<u>Coarse cemented gravel</u>		<u>3</u>	<u>10</u>	
<u>Brown clay (hard)</u>		<u>10</u>	<u>136</u>	
<u>white clay</u>		<u>136</u>	<u>145</u>	
<u>Brown clay sand mix</u>		<u>145</u>	<u>200</u>	
<u>Brown clay thin sand</u>	<u>X</u>	<u>200</u>	<u>240</u>	

8. WELL CONSTRUCTION

Diameter hole 10 inches Total depth 240 feet
 Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>6 3/8</u> inches	<u>71</u> feet	<u>240</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type concrete
 Depth of seal 61 feet
 Gravel packed: Yes No
 Gravel packed from 61 feet to 240 feet

Perforations:
 Type perforation Fedex milled
 Size perforation 1/2 x 5
 From 220 feet to 240 feet
 From _____ feet to _____ feet

Date started 5/30 1987
 Date completed 6/4/ 1987

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL

Static water level 87 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature cell ° F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name R.D. Reynolds Contractor
 Address Wells, Nev. Contractor
 Nevada contractor's license number 014410
 Nevada contractor's drillers number 1390
 Nevada driller's license number 1390 Actual Driller
 Signed [Signature] Contractor
 Date 6/20/87

WELLER TEST

G.P.M. 12 Draw down 100 feet 3 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours